

STATE OF NEBRASKA

DEPARTMENT OF ROADS

John L. Craig, *Director*

1500 Highway 2


PO Box 94759

Lincoln NE 68509-4759

Phone: (402) 471-4567

FAX: (402) 479-4325

<http://www.dor.state.ne.us>



**Mike
Johanna**

May 6, 2005

Daniel Pelliccintti
President
Global Klip Distributors, Inc
7623 Ridge Avenue, 2nd Floor
Philadelphia, PA 19128

Ref: New Product Evaluation — NPE #0505001

Dear Mr. Pelliccintti:

This is to inform you the product evaluation of the product listed below has been completed.

Kodi Klip

This product has been reviewed and deemed acceptable for use, but will not be added to our Approved Products List.

Our Standard Specifications 707.03, Paragraph 3a, states: The Contractor shall place all reinforcement in the position shown in the plans, and it shall be held securely in position with plastic clips and blocking. Paragraph 3b, (6) states: Tie wire for epoxy coated bars shall be plastic coated. Plastic clips suitable for this purpose may be used.

If this product was supplied to a Contractor, they would be able to use this product, as per our Standard Specifications.

Should you have any questions please feel free to call me at: 402-479-4754

This evaluation is considered closed,

Thank you for your submittal.

Sincerely

Product Coordinator
Materials and Research Tech III
Nebraska Department of Roads